

MYHOME DRIVER FOR RTI				
	<i>SIRINFO</i>	<i>dealer x</i>	<i>dealer y</i>	<i>dealer z</i>
LIGHTNING				
On/Off	✓	✓	✓	✓
Toggle	✓	✓	✓	✓
DIMMER				
Set Level	✓	✓	✗	✓
Set Speed	✓	✗	✗	✗
Level UP	✓	✗	✗	✗
Level DOWN	✓	✗	✗	✗
SHADE				
Up	✓	✓	✓	✓
Down	✓	✓	✓	✓
Stop	✓	✓	✓	✓
SCENARIO				
Run	✓	✗	✗	✓
Stop	✓	✗	✗	✗
Enable	✓	✗	✗	✗
Disable	✓	✗	✗	✗
TEMPERATURE				
Central Unit (99 zone)	✓	✗	✓	✗
Master Probe	✓	✗	✗	✗
Set Temperature	✓	✗	✗	✗
Setpoint +	✓	✗	✗	✗
Setpoint -	✓	✗	✗	✗
Set Automatic Mode	✓	✗	✗	✗
Set Off Mode	✓	✗	✗	✗
Set Antifreeze Mode	✓	✗	✗	✗
Set Protection Mode	✓	✗	✗	✗
CEN				
Cen Command	✓	✗	✗	✓
Cen Plus Command	✓	✗	✗	✗
VARIABLES				
Connection with Gateway	✓	✗	✗	✗
Command Session	✓	✗	✗	✗
Light status	✓	✓	✓	✓
Scenario status	✓	✗	✗	✗
Shade status	✓	✓	✓	✓
Dry Contact Status	✓	✗	✗	✗
Dimmer Level	✓	✓	✗	✓
Error message from gateway	✓	✗	✗	✗

TEMPERATURE VARIABLES				
Current Temperature	✓	✗	✓	✗
Current Setpoint	✓	✗	✗	✗
Local Offset	✓	✗	✗	✗
Real Setpoint	✓	✗	✗	✗
Operation Mode	✓	✗	✗	✗
Actuator Status	✓	✗	✗	✗
EVENT				
Light ON	✓	✓	✗	✗
Light OFF	✓	✗	✗	✗
Shade UP	✓	✗	✓	✗
Shade DOWN	✓	✗	✓	✗
Shade Stop	✓	✗	✓	✗
Temp. Over MAX	✓	✗	✗	✗
Temp. Below MIN	✓	✗	✗	✗
Dry Contact ON	✓	✗	✗	✗
Dry Contact OFF	✓	✗	✗	✗
OpenWEBNet Message received	✓	✓	✗	✗
CEN Short Pressure	✓	✗	✗	✗
CEN Long Pressure	✓	✗	✗	✗
OTHER				
Number of supported BUS	9	1	1	1
Log/Debug available	✓	✗	✓	✓
Startup Delay of driver	✓	✗	✗	✗
Temperature Monitoring (MIN-MAX)	✓	✗	✗	✗
Send custom OpenWEBNet Command	✓	✓	✓	✓